Rapid Fire Seal RFS 640
by FISCHERWERKE GMBH & CO KG

Health Product Declaration v2.3

created via: HPDC Online Builder

HPD UNIQUE IDENTIFIER: 883198976
CLASSIFICATION: 07 84 00 Firestopping
PRODUCT DESCRIPTION: fischer rapid fire resistant sealant RFS 640 is a spray grade one part water based, fire rated sealant which has been design to provide smoke and fire protection on construction joints and service penetrations in both vertical and horizontal applications. Tested in accordance with ASTM E 814 (UL1479), ASTM E 1966 (UL 2079), ASTM E 2307, ASTM E 84 (UL723) the fischer RFS can provide up to 3 hours fire rating. Meeting the new requirements of ASTM E 1399, RFS 640 has been cycled tested up to 500 times, RFS 640 has also been tested at positive pressure with a minimum 0.01" (2.5 mPa) water i.a.w UL 2079 test standards..Can be used for internal applications and for conditions where dynamic movement may occur. RFS640 is supplied in various packaging sizes, Colors and languages and this HPD applies to all the variations.

Section 1: Summary

Basic Method / Product Threshold

CONTENT INVENTORY

Inventory Reporting Format
- ○ Nested Materials Method
- ◉ Basic Method

Threshold Disclosed Per
- ○ Material
- ◉ Product

Threshold Level
- ○ 100 ppm
- ○ 1,000 ppm
- ◉ Per GHS SDS
- ○ Other

Residuals/Impurities Evaluation
- ○ Completed
- ○ Partially Completed
- ◉ Not Completed

Explanation(s) provided :
- ◉ Yes ○ No

For all contents above the threshold, the manufacturer has:

Characterized ◉ Yes ○ No
Provided weight and role.

Screened ◉ Yes ○ No
Provided screening results using HPDC-approved methods.

Identified ○ Yes ◉ No
Provided name and CAS RN or other identifier.

CONTENT IN DESCENDING ORDER OF QUANTITY

Summary of product contents and results from screening individual chemical substances against HPD Priority Hazard Lists and the GreenScreen for Safer Chemicals®. The HPD does not assess whether using or handling this product will expose individuals to its chemical substances or any health risk. Refer to Section 2 for further details.

PRODUCT | **MATERIAL OR SUBSTANCE** | *RESIDUAL OR IMPURITY*
GREENSCREEN SCORE | HAZARD TYPE

RAPID FIRE SEAL RFS 640 [UNDISCLOSED BM-3dg **UNDISCLOSED**
BM-4 **UNDISCLOSED** LT-P1 | MUL | SKI | AQU | MAM | EYE **]**

Number of Greenscreen BM-4/BM3 contents ... 2

Contents highest-concern GreenScreen score(s) (BM-1, LT-1, LT-P1) ... LT-P1

Nanomaterial ... No

INVENTORY AND SCREENING NOTES:

RFS 640 is a spray grade one part water based, fire rated sealant.

VOLATILE ORGANIC COMPOUND (VOC) CONTENT

Material (g/l): 10 Regulatory (g/l): 250
Does the product contain exempt VOCs: No
Are colorants available that do not increase the VOC content of the base paint when tinted: N/A

CERTIFICATIONS AND COMPLIANCE *See Section 3 for additional listings.*

VOC emissions: CDPH Standard Method V1.2 (Section 01350/CHPS) - Classroom & Office scenario
VOC content: SCAQMD Rule 1168 Adhesive and Sealant Applications - Adhesives for Indoor Carpet, Carpet Pad Subfloor, VCT & Asphalt Tile, Dry Wall & Panel and Cove Base, as amended 1/7/05)

CONSISTENCY WITH OTHER PROGRAMS

No pre-checks completed or disclosed.

Third Party Verified?
- ○ Yes
- ◉ No

PREPARER: Self-Prepared
VERIFIER:
VERIFICATION #:

SCREENING DATE: 2025-04-04
PUBLISHED DATE: 2025-04-14
EXPIRY DATE: 2028-04-04

Section 2: Content in Descending Order of Quantity

This section lists contents in a product based on specific threshold(s) and reports detailed health information including hazards. This HPD uses the inventory method indicated above, which is one of three possible methods:

- *Basic Inventory method with Product-level threshold.*
- *Nested Material Inventory method with Product-level threshold*
- *Nested Material Inventory method with individual Material-level thresholds*

Definitions and requirements for the three inventory methods and requirements for each data field can be found in the HPD Open Standard version 2.3, available on the HPDC website at: www.hpd-collaborative.org/hpd-2-3-standard

RAPID FIRE SEAL RFS 640

PRODUCT THRESHOLD: Per GHS SDS RESIDUALS AND IMPURITIES EVALUATION COMPLETED: No

RESIDUALS AND IMPURITIES NOTES: Based on an evaluation of raw material component information, no residuals and or impurities have been found.

OTHER PRODUCT NOTES: Based on an evaluation of raw material component information, no residuals and or impurities have been found.

UNDISCLOSED

ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-04-04 4:30:32**

%: **50.0000 - 60.0000** GreenScreen: **BM-3dg** RC: **None** NANO: **No** SUBSTANCE ROLE: **Filler**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: Filler.

UNDISCLOSED

ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-04-04 4:33:12**

%: **15.0000 - 20.0000** GreenScreen: **BM-4** RC: **None** NANO: **No** SUBSTANCE ROLE: **Solvent**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
EXEMPT	European Union / European Commission (EU EC)	EU - REACH Exemptions Exempted from REACH Annex IV listing due to intrinsic safety

SUBSTANCE NOTES: Solvent.

UNDISCLOSED ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-04-04 4:35:31**

%: **10.0000 - 20.0000** GreenScreen: **LT-P1** RC: **None** NANO: **No** SUBSTANCE ROLE: **Binder**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
MUL	German FEA - Substances Hazardous to Waters	Class 2 - Hazard to Waters
SKI	EU - GHS (H-Statements) Annex 6 Table 3-1	H314 - Causes severe skin burns and eye damage [Skin corrosion/irritation - Category 1A or 1B or 1C]
AQU	EU - GHS (H-Statements) Annex 6 Table 3-1	H400 - Very toxic to aquatic life [Hazardous to the aquatic environment (acute) - Category 1]
AQU	EU - GHS (H-Statements) Annex 6 Table 3-1	H410 - Very toxic to aquatic life with long lasting effects [Hazardous to the aquatic environment (chronic) - Category 1]
MAM	EU - GHS (H-Statements) Annex 6 Table 3-1	H301 - Toxic if swallowed [Acute toxicity (oral) - Category 3]
EYE	EU - GHS (H-Statements) Annex 6 Table 3-1	H318 - Causes serious eye damage [Serious eye damage/eye irritation - Category 1]
MAM	EU - GHS (H-Statements) Annex 6 Table 3-1	H330 - Fatal if inhaled [Acute toxicity (inhalation) - Category 1 or 2]
MAM	EU - GHS (H-Statements) Annex 6 Table 3-1	H310 - Fatal in contact with skin [Acute toxicity (dermal) - Category 1 or 2]
SKI	GHS - Australia	H314 - Causes severe skin burns and eye damage [Skin corrosion/irritation - Category 1A or 1B or 1C]
AQU	GHS - Australia	H410 - Very toxic to aquatic life with long lasting effects [Hazardous to the aquatic environment (chronic) - Category 1]
AQU	GHS - Korea	H400 - Very toxic to aquatic life [Hazardous to the aquatic environment (acute) - Category 1]
AQU	GHS - Korea	H410 - Very toxic to aquatic life with long lasting effects [Hazardous to the aquatic environment (chronic) - Category 1]
SKI	GHS - Korea	H314 - Causes severe skin burns and eye damage [Skin corrosion/irritation - Category 1]
MAM	GHS - Korea	H301 - Toxic if swallowed [Acute toxicity (oral) - Category 3]
MAM	GHS - Australia	H301 - Toxic if swallowed [Acute toxicity (oral) - Category 3]
MAM	GHS - Korea	H330 - Fatal if inhaled [Acute toxicity (inhalation) - Category 2]
MAM	GHS - Australia	H330 - Fatal if inhaled [Acute toxicity (inhalation) - Category 1 or 2]
MAM	GHS - Korea	H310 - Fatal in contact with skin [Acute toxicity (dermal) - Category 1]
MAM	GHS - Australia	H310 - Fatal in contact with skin [Acute toxicity (dermal) - Category 1 or 2]

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
RESTRICTED LIST	Green Science Policy Institute (GSPI)	GSPI - Six Classes Precautionary List Antimicrobials
RESTRICTED LIST	Cradle to Cradle Products Innovation Institute (C2CPII)	C2C Certified v4.0 Product Standard Restricted Substances List (RSL) - Effective July 1, 2022 Core Restrictions

SUBSTANCE NOTES: Binder

Section 3: Certifications and Compliance

This section lists applicable certification and standards compliance information for VOC emissions and VOC content. Other types of health or environmental performance testing or certifications completed for the product may be provided.

VOC EMISSIONS — **CDPH Standard Method V1.2 (Section 01350/CHPS) - Classroom & Office scenario**

CERTIFYING PARTY: Third Party
APPLICABLE FACILITIES: Wimpey Laboratories LLC Dubai
CERTIFICATE URL:

ISSUE DATE: 2023-07-27 00:00:00
EXPIRY DATE:

CERTIFIER OR LAB: Wimpey Laboratories LLC Dubai

CERTIFICATION AND COMPLIANCE NOTES:

VOC CONTENT — **SCAQMD Rule 1168 Adhesive and Sealant Applications - Adhesives for Indoor Carpet, Carpet Pad Subfloor, VCT & Asphalt Tile, Dry Wall & Panel and Cove Base, as amended 1/7/05)**

CERTIFYING PARTY: Third Party
APPLICABLE FACILITIES: Al Futtaim Element Dubai
CERTIFICATE URL:

ISSUE DATE: 2023-07-24 00:00:00
EXPIRY DATE:

CERTIFIER OR LAB: Al Futtaim Element Dubai

CERTIFICATION AND COMPLIANCE NOTES:

Section 4: Accessories

This section lists related products or materials that the manufacturer requires or recommends for installation (such as adhesives or fasteners), maintenance, cleaning, or operations. For information relating to the contents of these related products, refer to their applicable Health Product Declarations, if available.

No accessories are required for this product.

Section 5: General Notes

fischer rapid fire resistant sealant RFS 640 is a spray grade one part water based, fire rated sealant which has been design to provide smoke and fire protection on construction joints and service penetrations in both vertical and horizontal applications. Tested in accordance with ASTM E 814 (UL1479), ASTM E 1966 (UL 2079), ASTM E 2307, ASTM E 84 (UL723) the fischer RFS can provide up to 3 hours fire rating. Meeting the new requirements of ASTM E 1399, RFS 640 has been cycled tested up to 500 times, RFS 640 has also been tested at positive pressure with a minimum 0.01" (2.5 mPa) water i.a.w UL 2079 test standards..Can be used for internal applications and for conditions where dynamic movement may occur.

RFS640 is supplied in various packaging sizes, Colors and languages and this HPD applies to all the variations.

Specified Divisions:
Division 7 07 84 13 Penetration Firestopping
Division 22 22 00 00 Plumbing
Division 23 23 00 00 HVAC
Division 26 26 00 00 Electrical

Advantages:
Water based ; Flexible set ; Contains mould growth inhibitor ;Freeze - thaw capabilities ; Accelerated age and humidity tested ; Low VOC
Spray or brush applied ;Excellent smoke seal ;Water resistant

Section 6: References

MANUFACTURER INFORMATION

MANUFACTURER: **FISCHERWERKE GMBH & CO KG**
ADDRESS: **fischerwerke GmbH & Co. KG.**
Waldachtal, Waldachtal 72178
COUNTRY: **Germany**

WEBSITE: **www.fischer.ae**
CONTACT NAME: **Srihari Ega**
TITLE: **Business Development Manager -Bu Firestop**
PHONE: **971505561760**
EMAIL: **srihari.ega@fischer.ae**

The listed contact is responsible for the validity of this HPD and attests that it is accurate and complete to the best of his or her knowledge.

KEY

Hazard Types

AQU Aquatic toxicity
CAN Cancer
DEV Developmental toxicity
END Endocrine activity
EYE Eye irritation/corrosivity
GEN Gene mutation
GLO Global warming
LAN Land toxicity
MAM Mammalian/systemic/organ toxicity
MUL Multiple
NEU Neurotoxicity
NF Not found on Priority Hazard Lists
OZO Ozone depletion
PBT Persistent, bioaccumulative, and toxic
PHY Physical hazard (flammable or reactive)
REP Reproductive
RES Respiratory sensitization
SKI Skin sensitization/irritation/corrosivity
UNK Unknown

GreenScreen (GS)

BM-4 Benchmark 4 (prefer-safer chemical)
BM-3 Benchmark 3 (use but still opportunity for improvement)
BM-2 Benchmark 2 (use but search for safer substitutes)
BM-1 Benchmark 1 (avoid - chemical of high concern)
BM-U Benchmark Unspecified (due to insufficient data)
LT-P1 List Translator Possible 1 (Possible Benchmark-1)
LT-1 List Translator 1 (Likely Benchmark-1)
LT-UNK List Translator Benchmark Unknown
NoGS No GreenScreen.

GreenScreen Benchmark scores sometimes also carry subscripts, which provide more context for how the score was determined. These are DG (data gap), TP (transformation product), and CoHC (chemical of high concern). For more information, see 2.2.2.4 GreenScreen® for Safer Chemicals, www.greenscreenchemicals.org, and Best Practices for Hazard Screening on the HPDC website (hpd-collaborative.org).

Recycled Types

PreC Pre-consumer recycled content
PostC Post-consumer recycled content
UNK Inclusion of recycled content is unknown
None Does not include recycled content

Other Terms:

GHS SDS Globally Harmonized System of Classification and Labeling of Chemicals Safety Data Sheet

Inventory Methods:

Nested Method / **Material Threshold** Substances listed within each material per threshold indicated per material
Nested Method / **Product Threshold** Substances listed within each material per threshold indicated per product
Basic Method / **Product Threshold** Substances listed individually per threshold indicated per product

Nano Composed of nano scale particles or nanotechnology
Third Party Verified Verification by independent certifier approved by HPDC
Preparer Third party preparer, if not self-prepared by manufacturer
Applicable facilities Manufacturing sites to which testing applies

The Health Product Declaration (HPD) Open Standard provides for the disclosure of product contents and potential associated human and environmental health hazards. Hazard associations are based on the HPD Priority Hazard Lists, the GreenScreen List Translator™, and when available, full GreenScreen® assessments. The HPD Open Standard v2.1 is not:

- *a method for the assessment of exposure or risk associated with product handling or use,*
- *a method for assessing potential health impacts of: (i) substances used or created during the manufacturing process or (ii) substances created after the product is delivered for end use.*

Information about life cycle, exposure and/or risk assessments performed on the product may be reported by the manufacturer in appropriate Notes sections, and/or, where applicable, in the Certifications section.

The HPD Open Standard was created and is supported by the Health Product Declaration Collaborative (the HPD Collaborative), a customer-led organization composed of stakeholders throughout the building industry that is committed to the continuous improvement of building products through transparency, openness, and innovation throughout the product supply chain.

The product manufacturer and any applicable independent verifier are solely responsible for the accuracy of statements and claims made in this HPD and

for compliance with the HPD standard noted.