EZ-Path® Series 22 Fire Rated Pathway by Specified Technologies Inc.

SCREENING DATE: 2025-11-21
PUBLISHED DATE: 2025-11-21
EXPIRY DATE: 2028-11-21
PREPARER: Self-Prepared

Health Product Declaration v3.0
created via: HPDC Online Builder

HPD UNIQUE IDENTIFIER: 700342272
HPD UNIQUE PRODUCT ID: Not provided.
CLASSIFICATION: 07 84 13.16 Penetration Firestopping Devices
PRODUCT DESCRIPTION: The EZ Path® Series 22 Fire Rated Pathway is a pathway device designed to allow cables to penetrate fire-rated walls without the need for firestopping. This device features a built-in fire sealing system that automatically adjusts to the amount of cables installed. Once installed in a fire barrier, cables can be easily added or removed at any time without the need to remove or reinstall firestopping materials. The EZ Path® Series 22 Fire Rated Pathway consists of an enclosed heavy gauge galvanized steel pathway lined with intumescent material engineered for rapid expansion when exposed to fire or high temperatures, quickly sealing the pathway and preventing the passage of flames and smoke.

Section 1: Summary

Basic Method / Product Threshold

CONTENT INVENTORY

Inventory Reporting Format
→ Basic Method

Threshold Disclosed Per
→ Product

Threshold Level
→ 1,000 ppm

Residuals/Impurities Evaluation
→ Completed

Explanation(s) provided :
Yes

For all contents above the threshold, the manufacturer has:

Characterized Yes
Provided weight and role.

Screened Yes
Provided screening results using HPDC-approved methods.

Identified No
Provided name and CAS RN or other identifier.

CONTENT IN DESCENDING ORDER OF QUANTITY

Summary of product contents and results from screening individual chemical substances against HPD Priority Hazard Lists and the GreenScreen for Safer Chemicals®. The HPD does not assess whether using or handling this product will expose individuals to its chemical substances or any health risk. Refer to Section 2 for further details.

PRODUCT | **MATERIAL OR SUBSTANCE** | *RESIDUAL OR IMPURITY*
GREENSCREEN SCORE | HAZARD TYPE

EZ-PATH® SERIES 22 FIRE RATED PATHWAY [STEEL NoGS
GRAPHITE LT-UNK **UNDISCLOSED** BM-2 **UNDISCLOSED** LT-UNK
UNDISCLOSED LT-UNK | CAN | RES | SKI | EYE | MAM **UNDISCLOSED**
LT-UNK | SKI | EYE | CAN | MAM **CARBON BLACK** BM-1 | CAN | EYE |
MAM | PHY **2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN** BM-1 | END |
REP | MUL | EYE **UNDISCLOSED** LT-UNK | SKI | EYE | MAM | REP
UNDISCLOSED LT-UNK | EYE **2,5-FURANDIONE, 3-**
(DODECENYL)DIHYDRO- LT-UNK **POLYPROPYLENE GLYCOL** LT-
UNK | EYE **]**

Number of Greenscreen BM-4/BM3 contents ... 0

Contents highest-concern GreenScreen score(s) (BM-1, LT-1, LT-P1) ... BM-1

Nanomaterial ... No

INVENTORY AND SCREENING NOTES:

None.

VOLATILE ORGANIC COMPOUND (VOC) CONTENT

VOC Content data is not applicable for this product category.

COMPLIANCE *See Section 3 for additional listings.*

VOC emissions: N/A

CONSISTENCY WITH OTHER PROGRAMS

No pre-checks completed or disclosed.

Section 2: Content in Descending Order of Quantity

This section lists contents in a product based on specific threshold(s) and reports detailed health information including hazards. This HPD uses the inventory method indicated above, which is one of three possible methods:

- *Basic Inventory method with Product-level threshold.*
- *Nested Material Inventory method with Product-level threshold*
- *Nested Material Inventory method with individual Material-level thresholds*

Definitions and requirements for the three inventory methods and requirements for each data field can be found in the HPD Open Standard version 3.0, available on the HPDC website at: www.hpd-collaborative.org/hpd-3-0-standard

EZ-PATH® SERIES 22 FIRE RATED PATHWAY

PRODUCT THRESHOLD: 1000 ppm

RESIDUALS AND IMPURITIES EVALUATION COMPLETED: Yes

RESIDUALS AND IMPURITIES NOTES: No residuals are found in this product.

OTHER PRODUCT NOTES: No residuals are found in this product.

STEEL

ID: **12597-69-2**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2025-11-21 14:47:10**

%: **70.0000 - 75.0000** GreenScreen: **NoGS** RC: **None** NANO: **No** SUBSTANCE ROLE: **Hardware**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: The is the steel casing for the product.

GRAPHITE

ID: **7782-42-5**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2025-11-21 14:47:10**

%: **4.0000 - 6.0000** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Intumescent**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: This is the intumescent in the device.

UNDISCLOSED

ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:11**

%: **3.0000 - 5.0000** GreenScreen: **BM-2** RC: **None** NANO: **No** SUBSTANCE ROLE: **Plasticizer**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: This is a plasticizer in the product.

UNDISCLOSED

ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:11**

%: **3.0000 - 5.0000** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Binder**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: This is part of the intumescent binder in the product.

UNDISCLOSED

ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:12**

%: **1.0000 - 2.0000** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Binder**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
CAN	MAK	Carcinogen Group 4 - Non-genotoxic carcinogen with low risk under MAK/BAT levels
RES	MAK	Sensitizing Substance Sah - Danger of airway & skin sensitization
SKI	EU - GHS (H-Statements) Annex 6 Table 3-1	H315 - Causes skin irritation [Skin corrosion/irritation - Category 2]
EYE	EU - GHS (H-Statements) Annex 6 Table 3-1	H319 - Causes serious eye irritation [Serious eye damage/eye irritation - Category 2A]
CAN	EU - GHS (H-Statements) Annex 6 Table 3-1	H351 - Suspected of causing cancer [Carcinogenicity - Category 2]
SKI	GHS - New Zealand	Skin irritation category 2
EYE	GHS - New Zealand	Eye irritation category 2

SKI	GHS - Australia	H315 - Causes skin irritation [Skin corrosion/irritation - Category 2]
EYE	GHS - Australia	H319 - Causes serious eye irritation [Serious eye damage/eye irritation - Category 2A]
CAN	GHS - New Zealand	Carcinogenicity category 2
MAM	GHS - Japan	H372 - Causes damage to organs through prolonged or repeated exposure [Specific target organs/systemic toxicity following repeated exposure - Category 1]
MAM	GHS - Australia	H372 - Causes damage to organs through prolonged or repeated exposure [Specific target organ toxicity - repeated exposure - Category 1]
MAM	GHS - New Zealand	Specific target organ toxicity - repeated exposure category 1
MAM	GHS - Japan	H370 - Causes damage to organs [Specific target organs/systemic toxicity following single exposure - Category 1]
CAN	EU - Annex VI CMRs	Carcinogen Category 2 - Suspected human Carcinogen
SKI	GHS - Japan	H315 - Causes skin irritation [Skin corrosion / irritation - Category 2]
SKI	GHS - New Zealand	Skin sensitisation category 1
MAM	GHS - New Zealand	Acute inhalation toxicity category 2
EYE	GHS - Korea	H319 - Causes serious eye irritation [Serious eye damage/irritation - Category 2]
SKI	GHS - Korea	H315 - Causes skin irritation [Skin corrosion/irritation - Category 2]
MAM	Québec CSST - WHMIS 1988	Class D1A - Very toxic material causing immediate and serious toxic effects
MAM	GHS - Australia	H330 - Fatal if inhaled [Acute toxicity (inhalation) - Category 1 or 2]
MAM	GHS - Japan	H330 - Fatal if inhaled [Acute toxicity (inhalation: dust, mist) - Category 2]
CAN	GHS - Australia	H351 - Suspected of causing cancer [Carcinogenicity - Category 2]
MAM	GHS - Korea	H335 - May cause respiratory irritation [Specific target organ toxicity - Single exposure - Category 3]

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
RESTRICTED LIST	Perkins+Will (P+W)	P&W - Precautionary List Precautionary list of substances recommended for avoidance
RESTRICTED LIST	Cradle to Cradle Products Innovation Institute (C2CPII)	C2C Certified v4.1 Product Standard Restricted Substances - Effective July 1, 2025 All Products
RESTRICTED LIST	Cradle to Cradle Products Innovation Institute (C2CPII)	C2C Certified v4.1 Product Standard Restricted Substances - Effective July 1, 2025 Cosmetics and Personal Care Products

SUBSTANCE NOTES: This is part of the intumescent binder in the product.

UNDISCLOSED ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:11**

%: **0.3000 - 0.6000** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Binder**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
SKI	EU - GHS (H-Statements) Annex 6 Table 3-1	H315 - Causes skin irritation [Skin corrosion/irritation - Category 2]
EYE	EU - GHS (H-Statements) Annex 6 Table 3-1	H319 - Causes serious eye irritation [Serious eye damage/eye irritation - Category 2A]
CAN	EU - GHS (H-Statements) Annex 6 Table 3-1	H351 - Suspected of causing cancer [Carcinogenicity - Category 2]
SKI	GHS - New Zealand	Skin irritation category 2
EYE	GHS - New Zealand	Eye irritation category 2
SKI	GHS - Australia	H315 - Causes skin irritation [Skin corrosion/irritation - Category 2]
EYE	GHS - Australia	H319 - Causes serious eye irritation [Serious eye damage/eye irritation - Category 2A]
CAN	GHS - New Zealand	Carcinogenicity category 2
MAM	GHS - Australia	H372 - Causes damage to organs through prolonged or repeated exposure [Specific target organ toxicity - repeated exposure - Category 1]
MAM	GHS - New Zealand	Specific target organ toxicity - repeated exposure category 1
CAN	EU - Annex VI CMRs	Carcinogen Category 2 - Suspected human Carcinogen
SKI	GHS - Japan	H315 - Causes skin irritation [Skin corrosion / irritation - Category 2]
SKI	GHS - New Zealand	Skin sensitisation category 1
MAM	GHS - New Zealand	Acute inhalation toxicity category 2
MAM	GHS - Australia	H330 - Fatal if inhaled [Acute toxicity (inhalation) - Category 1 or 2]
MAM	GHS - Japan	H330 - Fatal if inhaled [Acute toxicity (inhalation: dust, mist) - Category 2]
CAN	GHS - Australia	H351 - Suspected of causing cancer [Carcinogenicity - Category 2]

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
RESTRICTED LIST	Perkins+Will (P+W)	P&W - Precautionary List Precautionary list of substances recommended for avoidance
RESTRICTED LIST	Cradle to Cradle Products Innovation Institute (C2CPII)	C2C Certified v4.1 Product Standard Restricted Substances - Effective July 1, 2025 All Products
RESTRICTED LIST	Cradle to Cradle Products Innovation Institute (C2CPII)	C2C Certified v4.1 Product Standard Restricted Substances - Effective July 1, 2025 Cosmetics and Personal Care Products

SUBSTANCE NOTES: This is part of the intumescent binder in the product.

CARBON BLACK

ID: **1333-86-4**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:11**

%: **0.2000 - 0.4000** GreenScreen: **BM-1** RC: **None** NANO: **No** SUBSTANCE ROLE: **Pigment**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
CAN	US CDC - Occupational Carcinogens	Occupational Carcinogen
CAN	MAK	Carcinogen Group 3B - Evidence of carcinogenic effects but not sufficient for classification
CAN	CA EPA - Prop 65	Carcinogen - specific to chemical form or exposure route
CAN	IARC	Group 2b - Possibly carcinogenic to humans
EYE	GHS - New Zealand	Eye irritation category 2
CAN	GHS - New Zealand	Carcinogenicity category 2
CAN	GHS - Japan	H351 - Suspected of causing cancer [Carcinogenicity - Category 2]
MAM	GHS - Japan	H372 - Causes damage to organs through prolonged or repeated exposure [Specific target organs/systemic toxicity following repeated exposure - Category 1]
PHY	GHS - Japan	H251 - Self-heating;; may catch fire [Self-heating substances and mixtures - Category 1]

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: This is part of the intumescent binder in the product.

2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN

ID: **119-47-1**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:12**

%: **0.2000 - 0.4000** GreenScreen: **BM-1** RC: **None** NANO: **No** SUBSTANCE ROLE: **Antioxidant**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
END	TEDX - Potential Endocrine Disruptors	Potential Endocrine Disruptor
REP	EU - Annex VI CMRs	Reproductive Toxicity - Category 1B
MUL	ChemSec - SIN List	CMR - Carcinogen, Mutagen &/or Reproductive Toxicant
MUL	German FEA - Substances Hazardous to Waters	Class 2 - Hazard to Waters
REP	GHS - Japan	H360 - May damage fertility or the unborn child [Toxic to reproduction - Category 1B]
REP	GHS - Australia	H360F - May damage fertility [Reproductive toxicity - Category 1A or 1B]
REP	EU - GHS (H-Statements) Annex 6 Table 3-1	H360F - May damage fertility [Reproductive toxicity - Category 1A or 1B]
EYE	GHS - New Zealand	Eye irritation category 2
REP	GHS - New Zealand	Reproductive toxicity category 2
REP	EU - SVHC List	Toxic to reproduction - Candidate list
REP	EU - REACH Annex XVII CMRs	Reproductive toxicants: Category 1B

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
RESTRICTED LIST	Cradle to Cradle Products Innovation Institute (C2CPII)	C2C Certified v4.1 Product Standard Restricted Substances - Effective July 1, 2025 All Products
RESTRICTED LIST	Cradle to Cradle Products Innovation Institute (C2CPII)	C2C Certified v4.1 Product Standard Restricted Substances - Effective July 1, 2025 Cosmetics and Personal Care Products

SUBSTANCE NOTES: No residuals are found in this material.

UNDISCLOSED ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:12**

%: **0.2000 - 0.3000** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Catalyst**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
SKI	GHS - New Zealand	Skin irritation category 2
EYE	GHS - New Zealand	Eye irritation category 2
MAM	GHS - Japan	H372 - Causes damage to organs through prolonged or repeated exposure [Specific target organs/systemic toxicity following repeated exposure - Category 1]
SKI	GHS - Japan	H315 - Causes skin irritation [Skin corrosion / irritation - Category 2]
MAM	GHS - Japan	H371 - May cause damage to organs [Specific target organs/systemic toxicity following single exposure - Category 2]
REP	GHS - Japan	H361 - Suspected of damaging fertility or the unborn child [Toxic to reproduction - Category 2]

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: This is part of the intumescent binder in the product.

UNDISCLOSED ID: **Undisclosed**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:13**

%: **0.1000 - 0.2000** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Carrier**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
EYE	GHS - New Zealand	Eye irritation category 2

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
RESTRICTED LIST	Green Science Policy Institute (GSPI)	GSPI - Six Classes Precautionary List Antimicrobials
RESTRICTED LIST	Green Science Policy Institute (GSPI)	GSPI - Six Classes Precautionary List Some Solvents

SUBSTANCE NOTES: No residuals are found in this material.

2,5-FURANDIONE, 3-(DODECENYL)DIHYDRO- ID: **25377-73-5**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:12**

%: **0.0500 - 0.1500** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Surfactant**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
None found		No listings found on Additional Hazard Lists

SUBSTANCE NOTES: No residuals are found in this material.

POLYPROPYLENE GLYCOL

ID: **25322-69-4**

HAZARD DATA SOURCE: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2025-11-21 14:47:13**

%: **0.0500 - 0.1500** GreenScreen: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Binder**

HAZARD TYPE	LIST NAME AND SOURCE	WARNINGS
EYE	GHS - New Zealand	Eye irritation category 2

ADDITIONAL LISTINGS	LIST NAME AND SOURCE	NOTIFICATION
RESTRICTED LIST	Green Science Policy Institute (GSPI)	GSPI - Six Classes Precautionary List Some Solvents

SUBSTANCE NOTES: This is part of the intumescent binder in the product.

Section 3: Compliance

This section lists applicable certification and standards compliance information for VOC emissions and VOC content. Other types of health or environmental performance testing or certifications completed for the product may be provided.

VOC EMISSIONS	N/A

COMPLIANCE TYPE: Self-declared
CERTIFIER/VERIFIER/TESTING LAB/AUDITOR: Self-declared.
COMPLIANCE DETAILS:
COMPLIANCE SCOPE:
APPLICABLE FACILITIES: All.
COMPLIANCE URL:
https://files.stifirestop.com/5.%20Safety%20Data%20Sheets/1.%20English/SDS_EZ-Path%2044+.pdf
COMPLIANCE NOTES: Not Applicable.

ISSUE DATE: 2017-05-05

EXPIRY DATE: No expiration

Section 4: Accessories

This section lists related products or materials that the manufacturer requires or recommends for installation (such as adhesives or fasteners), maintenance, cleaning, or operations. For information relating to the contents of these related products, refer to their applicable Health Product Declarations, if available.

No accessories are required for this product.

Section 5: General Notes

EZ Path® Series 22 Fire Rated Pathway is painted safety orange for easy identification. Its compact square profile allows a maximum number of cables to be installed in a relatively small area. The pathway measures approximately 1-1/2” x 1-1/2” (37 mm) and is 10-1/2” (267 mm) long.
Applications
EZ Path® Series 22 Fire Rated Pathway is designed for easy installation in walls. Tested and approved cable capacities range from 0 to 100% visual fill.
EZ Path® Series 22 Fire Rated Pathway when installed with provided wall plates is designed for
new cable installations. In these installations, the device does not require mechanical attachment to either the wall or the wall framing and may be installed after the wallboard has been installed. EZ Path® Series 22’s split body design also allows the
device to be easily disassembled and installed around previously installed cables in
existing construction.
EZ Path® Series 22 Fire Rated Pathway provides exceptional cable capacity. A single unit installed in a wall has an equal cable carrying capacity of a 2” (50 mm) diam sleeve utilizing typical putty firestop systems (35% cable loading).
Specifications
All data, video, and communications cable bundles shall utilize an enclosed firerated pathway device wherever said cables penetrate rated walls. The fire-rated pathway shall contain a built-in fire sealing system sufficient to maintain the hourly fire rating of the barrier being penetrated. The self-contained sealing system shall automatically adjust to the installed cable loading and shall permit cables to be installed, removed, or retrofitted without the need to remove or reinstall firestop materials. The pathway shall be UL Certified and tested to the requirements of ASTM E814 (UL1479) and CAN/ULC S115.
Specified Divisions
Division 7 07 84 13 Penetration Firestopping
Division 26 26 00 00 Electrical
Division 27 27 00 00 Communications
Performance:
EZ Path® Series 22 Fire Rated Pathway is UL Tested and Certified in accordance with ASTM E814 (UL1479) and CAN/ULC S115. Systems are available for common wall construction with ratings up to and including 4 hours.
Features & Benefits
• Easy to install
• No firestopping required
• Firestopped at all stages of use
• UL Tested - Low Leakage!
• UL Classified for the complete range of its capacity
• Match the capacity of a 2” (50 mm) conduit
• Acoustically Tested

Section 6: References

MANUFACTURER INFORMATION

MANUFACTURER: **Specified Technologies Inc.**
ADDRESS: **210 Evans Way**
Somerville, NJ 08876
COUNTRY: **USA**

WEBSITE: **www.stifirestop.com**
CONTACT NAME: **George Gornick, LEED Green Associate**
TITLE: **Applications Engineer**
PHONE: **800-992-1180 Ext. 1013**
EMAIL: **ggornick@stifirestop.com**

The listed contact is responsible for the validity of this HPD and attests that it is accurate and complete to the best of his or her knowledge.

KEY

Hazard Types

AQU Aquatic toxicity
CAN Cancer
DEV Developmental toxicity
END Endocrine activity
EYE Eye irritation/corrosivity
GEN Gene mutation
GLO Global warming
LAN Land toxicity
MAM Mammalian/systemic/organ toxicity
MUL Multiple
NEU Neurotoxicity
NF Not found on Priority Hazard Lists
OZO Ozone depletion
PBT Persistent, bioaccumulative, and toxic
PHY Physical hazard (flammable or reactive)
REP Reproductive
RES Respiratory sensitization
SKI Skin sensitization/irritation/corrosivity
UNK Unknown

GreenScreen (GS)

BM-4 Benchmark 4 (prefer-safer chemical)
BM-3 Benchmark 3 (use but still opportunity for improvement)
BM-2 Benchmark 2 (use but search for safer substitutes)
BM-1 Benchmark 1 (avoid - chemical of high concern)
BM-U Benchmark Unspecified (due to insufficient data)
LT-P1 List Translator Possible 1 (Possible Benchmark-1)
LT-1 List Translator 1 (Likely Benchmark-1)
LT-UNK List Translator Benchmark Unknown
NoGS No GreenScreen.

GreenScreen Benchmark scores sometimes also carry subscripts, which provide more context for how the score was determined. These are DG (data gap), TP (transformation product), and CoHC (chemical of high concern). For more information, see 2.2.2.4 GreenScreen® for Safer Chemicals, www.greenscreenchemicals.org, and Best Practices for Hazard Screening on the HPDC website (hpd-collaborative.org).

Recycled Types

PreC Pre-consumer recycled content
PostC Post-consumer recycled content
UNK Inclusion of recycled content is unknown
None Does not include recycled content

Other Terms:

GHS SDS Globally Harmonized System of Classification and Labeling of Chemicals Safety Data Sheet

Inventory Methods:

Nested Method / **Material Threshold** Substances listed within each material per threshold indicated per material
Nested Method / **Product Threshold** Substances listed within each material per threshold indicated per product
Basic Method / **Product Threshold** Substances listed individually per threshold indicated per product

Nano Composed of nano scale particles or nanotechnology
Third Party Verified Verification by independent certifier approved by HPDC
Preparer Third party preparer, if not self-prepared by manufacturer
Applicable facilities Manufacturing sites to which testing applies

The Health Product Declaration (HPD) Open Standard provides for the disclosure of product contents and potential associated human and environmental health hazards. Hazard associations are based on the HPD Priority Hazard Lists, the GreenScreen List Translator™, and when available, full GreenScreen® assessments. The HPD Open Standard v2.1 is not:

- *a method for the assessment of exposure or risk associated with product handling or use,*
- *a method for assessing potential health impacts of: (i) substances used or created during the manufacturing process or (ii) substances created after the product is delivered for end use.*

Information about life cycle, exposure and/or risk assessments performed on the product may be reported by the manufacturer in appropriate Notes sections, and/or, where applicable, in the Certifications section.

The HPD Open Standard was created and is supported by the Health Product Declaration Collaborative (the HPD Collaborative), a customer-led organization composed of stakeholders throughout the building industry that is committed to the continuous improvement of building products through transparency, openness, and innovation throughout the product supply chain.

The product manufacturer and any applicable independent verifier are solely responsible for the accuracy of statements and claims made in this HPD and for compliance with the HPD standard noted.