SpecSeal® Series SSW BLU2 Intumescent Wrap Strip by Specified Technologies Inc.

Health Product Declaration v2.2

created via: HPDC Online Builder

HPD UNIQUE IDENTIFIER: 27514
CLASSIFICATION: 07 84 13 Penetration Firestopping
PRODUCT DESCRIPTION: SpecSeal® Wrap Strips are highly flexible, elastomeric strips designed to firestop combustible penetrations in fire-rated floors, floor/ceilings, and walls. Convenient 12' (3.7 m) rolls, or individually sized strips facilitate installation and minimize waste. These products utilize STI's fast responding intumescent technology, providing very responsive and highly directionalized expansion. Rapid expansion provides quick closure for burning combustible penetrants. When exposed to temperatures in excess of 250°F (121°C), the SpecSeal® Wrap Strip begins to expand (intumesce) rapidly to form a dense, highly insulative char. Free expansion varies according to the grade utilized (See Table A). Expansion continues up to temperatures of 1,000°F (538°C).

Section 1: Summary

Basic Method / Product Threshold

CONTENT INVENTORY

Inventory Reporting Format
- ○ Nested Materials Method
- ◉ Basic Method

Threshold Disclosed Per
- ○ Material
- ◉ Product

Threshold Level
- ○ 100 ppm
- ◉ 1,000 ppm
- ○ Per GHS SDS
- ○ Other

Residuals/Impurities
- ◉ Considered
- ○ Partially Considered
- ○ Not Considered

Explanation(s) provided for Residuals/Impurities?
- ◉ Yes ○ No

All Substances Above the Threshold Indicated Are:

Characterized ◉ Yes Ex/SC ○ Yes ○ No

% weight and role provided for all substances except SC substances characterized according to SC guidance.

Screened ◉ Yes Ex/SC ○ Yes ○ No

All substances screened using Priority Hazard Lists with results disclosed except SC substances screened according to SC guidance.

Identified ○ Yes Ex/SC ○ Yes ◉ No

One or more substances not disclosed by Name (Specific or Generic) and Identifier and/ or one or more Special Condition did not follow guidance.

CONTENT IN DESCENDING ORDER OF QUANTITY

Summary of product contents and results from screening individual chemical substances against HPD Priority Hazard Lists and the GreenScreen for Safer Chemicals®. The HPD does not assess whether using or handling this product will expose individuals to its chemical substances or any health risk. Refer to Section 2 for further details.

MATERIAL | SUBSTANCE | *RESIDUAL OR IMPURITY* GREENSCREEN SCORE | HAZARD TYPE

SPECSEAL® SERIES SSW BLU2 INTUMESCENT WRAP STRIP [
SYNTHETIC GRAPHITE LT-P1 | MUL
UNDISCLOSED LT-UNK
UNDISCLOSED NoGS
METHYLENE BISPHENYL DIISOCYANATE (PURE MDI) LT-UNK | MUL | RES | CAN | SKI | EYE
2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN BM-1 | END | REP]

Number of Greenscreen BM-4/BM3 contents ... 0

Contents highest concern GreenScreen Benchmark or List translator Score ... BM-1

Nanomaterial ... No

INVENTORY AND SCREENING NOTES:

Special conditions applied:

[LEED v4] "Yes ex/SC" result is due only to materials and substances for which Special Conditions were applied. Thus "Yes ex/SC" does not disqualify the product for the LEED v4 Materials and Resources Disclosure and Optimization credit, Option 1.

None.

VOLATILE ORGANIC COMPOUND (VOC) CONTENT

VOC Content data is not applicable for this product category.

CERTIFICATIONS AND COMPLIANCE *See Section 3 for additional listings.*

VOC emissions: N/A

CONSISTENCY WITH OTHER PROGRAMS

Pre-checked for LEED v4 Material Ingredients Option 1

Third Party Verified?
- ○ Yes
- ◉ No

PREPARER: Self-Prepared
VERIFIER:
VERIFICATION #:

SCREENING DATE: 2022-02-08
PUBLISHED DATE: 2022-02-08
EXPIRY DATE: 2025-02-08

Section 2: Content in Descending Order of Quantity

This section lists contents in a product based on specific threshold(s) and reports detailed health information including hazards. This HPD uses the inventory method indicated above, which is one of three possible methods:

- *Basic Inventory method with Product-level threshold.*
- *Nested Material Inventory method with Product-level threshold*
- *Nested Material Inventory method with individual Material-level thresholds*

Definitions and requirements for the three inventory methods and requirements for each data field can be found in the HPD Open Standard version 2.2, available on the HPDC website at: www.hpd-collaborative.org/hpd-2-2-standard

SPECSEAL® SERIES SSW BLU2 INTUMESCENT WRAP STRIP

PRODUCT THRESHOLD: 1000 ppm RESIDUALS AND IMPURITIES CONSIDERED: Yes

RESIDUALS AND IMPURITIES NOTES: There are no residuals in this product.

OTHER PRODUCT NOTES: There are no residuals in this product.

SYNTHETIC GRAPHITE ID: 7782-42-5

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2022-02-08 10:34:03**

%: **30.0000 - 60.0000** GS: **LT-P1** RC: **None** NANO: **No** SUBSTANCE ROLE: **Intumescent**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
MUL	ChemSec - SIN List	CMR - Carcinogen, Mutagen &/or Reproductive Toxicant

SUBSTANCE NOTES: This material is the intumescent in the product.

UNDISCLOSED ID: Undisclosed

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2022-02-08 10:34:03**

%: **20.0000 - 40.0000** GS: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Binder**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

SUBSTANCE NOTES: This material is part of the binder in the product.

UNDISCLOSED ID: Undisclosed

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2022-02-08 10:34:04**

%: **10.0000 - 30.0000** GS: **NoGS** RC: **None** NANO: **No** SUBSTANCE ROLE: **Plasticizer**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
None found		No warnings found on HPD Priority Hazard Lists

SUBSTANCE NOTES: This material is part of the plastizicer in the product.

METHYLENE BISPHENYL DIISOCYANATE (PURE MDI) ID: 101-68-8

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2022-02-08 10:34:04**

%: **1.0000 - 3.0000** GS: **LT-UNK** RC: **None** NANO: **No** SUBSTANCE ROLE: **Binder**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
MUL	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
RES	AOEC - Asthmagens	Asthmagen (G) - generally accepted
CAN	MAK	Carcinogen Group 4 - Non-genotoxic carcinogen with low risk under MAK/BAT levels
RES	MAK	Sensitizing Substance Sah - Danger of airway & skin sensitization
RES	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage
SKI	EU - GHS (H-Statements) Annex 6 Table 3-1	H315 - Causes skin irritation [Skin corrosion/irritation - Category 2]
SKI	EU - GHS (H-Statements) Annex 6 Table 3-1	H317 - May cause an allergic skin reaction [Skin sensitization - Category 1]
EYE	EU - GHS (H-Statements) Annex 6 Table 3-1	H319 - Causes serious eye irritation [Serious eye damage/eye irritation - Category 2A]
RES	EU - GHS (H-Statements) Annex 6 Table 3-1	H334 - May cause allergy or asthma symptoms or breathing difficulties if inhaled [Respiratory sensitization - Category 1]
CAN	EU - GHS (H-Statements) Annex 6 Table 3-1	H351 - Suspected of causing cancer [Carcinogenicity - Category 2]

SUBSTANCE NOTES: This material is part of the binder system in the product.

2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN ID: **119-47-1**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library** HAZARD SCREENING DATE: **2022-02-08 10:34:05**

%: **0.5000 - 1.5000** GS: **BM-1** RC: **None** NANO: **No** SUBSTANCE ROLE: **Antioxidant**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
END	TEDX - Potential Endocrine Disruptors	Potential Endocrine Disruptor
REP	GHS - Australia	H360F - May damage fertility [Reproductive toxicity - Category 1A or 1B]

SUBSTANCE NOTES: This material is the anti oxidant in the product.

Section 3: Certifications and Compliance

This section lists applicable certification and standards compliance information for VOC emissions and VOC content. Other types of health or environmental performance testing or certifications completed for the product may be provided.

VOC EMISSIONS **N/A**

CERTIFYING PARTY: Self-declared APPLICABLE FACILITIES: All. CERTIFICATE URL: https://files.stifirestop.com/5.%20Safety%20Data%20Sheets/1.%20English/SDS_BLU2%20Wrap%20Strip.pdf	ISSUE DATE:	EXPIRY DATE:	CERTIFIER OR LAB:
	2017-07-12		Self-declared.

CERTIFICATION AND COMPLIANCE NOTES: Not appilcable. Not a wet applied product or type of insulation. See SDS under Certificate URL.

Section 4: Accessories

This section lists related products or materials that the manufacturer requires or recommends for installation (such as adhesives or fasteners), maintenance, cleaning, or operations. For information relating to the contents of these related products, refer to their applicable Health Product Declarations, if available.

No accessories are required for this product.

Section 5: General Notes

Applications
SpecSeal® Wrap Strips are used for firestopping combustible penetrants such as nonmetallic pipes or pipe insulation. Installations were developed for both “tuck-in” applications (where strips are secured around the penetrant and slid into the opening) and restraining collar assemblies (for surface mounting). For larger openings or complex penetrant configurations, systems were developed utilizing wrap strips in conjunction with other SpecSeal® products. SpecSeal® Wrap Strips are suitable for use in all common forms of construction including concrete floors, concrete over steel deck, concrete walls, concrete block walls, gypsum board/stud walls, and wood floor/ ceiling assemblies.
Specifications
The wrap strip material shall be a highly flexible, intumescent material. The wrap strip shall contain no water soluble expansion ingredients and provide a minimum of 20x free expansion. The intumescent wrap strip shall be faced on each side with plastic.
The specified material shall be approved for a wide range of applications including combustible and noncombustible penetrants when used by itself or in combination with other products from the same manufacturer. The wrap strip shall be UL Certified and tested to the requirements of ASTM E814 (UL 1479), CAN/ULC S115.
Specified Divisions
Division 7 07 84 13 Penetration Firestopping
Division 22 22 00 00 Plumbing
Performance
SpecSeal® Wrap Strips are the basis for systems that meet the exacting criteria of ASTM E814 (UL 1479), CAN/ULC S115. Systems were tested for all common forms of construction and penetrants with ratings up to 4 hours (dependent upon grade of wrap strip utilized).
Features & Benefits
• Rapid Expansion: Closes off burning penetrants faster.
• High Volume Char: Significant expansion seals off opening!
• Water-Resistant: No soluble or hygroscopic ingredients.
• Economical: 12’ (3.7 m) rolls or precut strips means no piecing...less waste!
• Highly Flexible: No foil...soft...supple...easier to install!
• Versatile: Performer for a wide range of complex applications.

Section 6: References

MANUFACTURER INFORMATION

MANUFACTURER: **Specified Technologies Inc.**
ADDRESS: **210 Evans Way**
Somerville NJ 08876, United States
WEBSITE: **www.stifirestop.com**

CONTACT NAME: **George Gornick, LEED Green Associate**
TITLE: **Applications Engineer**
PHONE: **800-992-1180, Ext. 1013**
EMAIL: **ggornick@stifirestop.com**

The listed contact is responsible for the validity of this HPD and attests that it is accurate and complete to the best of his or her knowledge.

KEY

Hazard Types

AQU Aquatic toxicity
CAN Cancer
DEV Developmental toxicity
END Endocrine activity
EYE Eye irritation/corrosivity
GEN Gene mutation
GLO Global warming
LAN Land toxicity
MAM Mammalian/systemic/organ toxicity
MUL Multiple
NEU Neurotoxicity
NF Not found on Priority Hazard Lists
OZO Ozone depletion
PBT Persistent, bioaccumulative, and toxic
PHY Physical hazard (flammable or reactive)
REP Reproductive
RES Respiratory sensitization
SKI Skin sensitization/irritation/corrosivity
UNK Unknown

GreenScreen (GS)

BM-4 Benchmark 4 (prefer-safer chemical)
BM-3 Benchmark 3 (use but still opportunity for improvement)
BM-2 Benchmark 2 (use but search for safer substitutes)
BM-1 Benchmark 1 (avoid - chemical of high concern)
BM-U Benchmark Unspecified (due to insufficient data)
LT-P1 List Translator Possible 1 (Possible Benchmark-1)
LT-1 List Translator 1 (Likely Benchmark-1)
LT-UNK List Translator Benchmark Unknown (the chemical is present on at least one GreenScreen Specified List, but the information contained within the list did not result in a clear mapping to a LT-1 or LTP1 score.)
NoGS No GreenScreen.

Recycled Types

PreC Pre-consumer recycled content
PostC Post-consumer recycled content
UNK Inclusion of recycled content is unknown
None Does not include recycled content

Other Terms:

GHS SDS Globally Harmonized System of Classification and Labeling of Chemicals Safety Data Sheet

Inventory Methods:

Nested Method / Material Threshold Substances listed within each material per threshold indicated per material
Nested Method / Product Threshold Substances listed within each material per threshold indicated per product
Basic Method / Product Threshold Substances listed individually per threshold indicated per product

Nano Composed of nano scale particles or nanotechnology
Third Party Verified Verification by independent certifier approved by HPDC
Preparer Third party preparer, if not self-prepared by manufacturer
Applicable facilities Manufacturing sites to which testing applies

The Health Product Declaration (HPD) Open Standard provides for the disclosure of product contents and potential associated human and environmental health hazards. Hazard associations are based on the HPD Priority Hazard Lists, the GreenScreen List Translator™, and when available, full GreenScreen® assessments. The HPD Open Standard v2.1 is not:

- *a method for the assessment of exposure or risk associated with product handling or use,*
- *a method for assessing potential health impacts of: (i) substances used or created during the manufacturing process or (ii) substances created after the product is delivered for end use.*

Information about life cycle, exposure and/or risk assessments performed on the product may be reported by the manufacturer in appropriate Notes sections, and/or, where applicable, in the Certifications section.

The HPD Open Standard was created and is supported by the Health Product Declaration Collaborative (the HPD Collaborative), a customer-led organization composed of stakeholders throughout the building industry that is committed to the continuous improvement of building products through transparency, openness, and innovation throughout the product supply chain.

The product manufacturer and any applicable independent verifier are solely responsible for the accuracy of statements and claims made in this HPD and for compliance with the HPD standard noted.