

CLASSIFICATION: 07 84 00 Firestopping, 07 84 13 Penetration Firestopping, 07 84 13.16 Penetration Firestopping Devices

PRODUCT DESCRIPTION: The EZ Path® Series 22 Fire Rated Pathway is a pathway device designed to allow cables to penetrate fire-rated walls without the need for firestopping. This device features a built-in fire sealing system that automatically adjusts to the amount of cables installed. Once installed in a fire barrier, cables can be easily added or removed at any time without the need to remove or reinstall firestopping materials. The EZ Path® Series 22 Fire Rated Pathway consists of an enclosed heavy gauge galvanized steel pathway lined with intumescent material engineered for rapid expansion when exposed to fire or high temperatures, quickly sealing the pathway and preventing the passage of flames and smoke.

Section 1: Summary

Basic Method / Product Threshold

CONTENT INVENTORY

Inventory Reporting Format

- Nested Materials Method
 Basic Method

Threshold Disclosed Per

- Material
 Product

Threshold level

- 100 ppm
 1,000 ppm
 Per GHS SDS
 Per OSHA MSDS
 Other

Residuals/Impurities

- Considered
 Partially Considered
 Not Considered

Explanation(s) provided
for Residuals/Impurities?
 Yes No

All Substances Above the Threshold Indicated Are:

Characterized Yes Ex/SC Yes No
% weight and role provided for all substances.

Screened Yes Ex/SC Yes No
All substances screened using Priority Hazard Lists with results disclosed.

Identified Yes Ex/SC Yes No
One or more substances not disclosed by Name (Specific or Generic) and Identifier and/ or one or more Special Condition did not follow guidance.

CONTENT IN DESCENDING ORDER OF QUANTITY

Summary of product contents and results from screening individual chemical substances against HPD Priority Hazard Lists and the GreenScreen for Safer Chemicals®. The HPD does not assess whether using or handling this product will expose individuals to its chemical substances or any health risk. Refer to Section 2 for further details.

MATERIAL | SUBSTANCE | RESIDUAL OR IMPURITY
GREENSCREEN SCORE | HAZARD TYPE

EZ PATH® SERIES 22 FIRE RATED PATHWAY [GRAPHITE LT-UNK
UNDISCLOSED BM-2 UNDISCLOSED LT-UNK UNDISCLOSED LT-UNK |
RES | MUL | SKI | EYE | CAN UNDISCLOSED LT-UNK | MUL | SKI | EYE | RES
| CAN UNDISCLOSED LT-UNK CARBON BLACK LT-1 | CAN 2,2'-BIS-6-
TERC.BUTYL-P-KRESYLMETHAN LT-P1 | END | REP UNDISCLOSED LT-
UNK 2,5-FURANDIONE, 3-(DODECENYL)DIHYDRO- LT-UNK
POLYPROPYLENE GLYCOL LT-UNK]

Number of Greenscreen BM-4/BM3 contents ... 0

Contents highest concern GreenScreen
Benchmark or List translator Score ... LT-1

Nanomaterial ... No

INVENTORY AND SCREENING NOTES:

None.

VOLATILE ORGANIC COMPOUND (VOC) CONTENT

VOC Content data is not applicable for this product category.

CERTIFICATIONS AND COMPLIANCE See Section 3 for additional listings.

VOC emissions: N/A

CONSISTENCY WITH OTHER PROGRAMS

Pre-checked for LEED v4 Material Ingredients, Option 1

Third Party Verified?

- Yes
 No

PREPARER: Self-Prepared

VERIFIER:

VERIFICATION #:

SCREENING DATE: 2018-11-16

PUBLISHED DATE: 2018-11-19

EXPIRY DATE: 2021-11-16



Section 2: Content in Descending Order of Quantity

This section lists contents in a product based on specific threshold(s) and reports detailed health information including hazards. This HPD uses the inventory method indicated above, which is one of three possible methods:

- Basic Inventory method with Product-level threshold.
- Nested Material Inventory method with Product-level threshold
- Nested Material Inventory method with individual Material-level thresholds

Definitions and requirements for the three inventory methods and requirements for each data field can be found in the HPD Open Standard version 2.1, available on the HPDC website at: www.hpd-collaborative.org/hpd-2-1-standard

EZ PATH® SERIES 22 FIRE RATED PATHWAY

PRODUCT THRESHOLD: 1000 ppm

RESIDUALS AND IMPURITIES CONSIDERED: Yes

RESIDUALS AND IMPURITIES NOTES: No residuals are found in this product.

OTHER PRODUCT NOTES: No residuals are found in this product.

GRAPHITE

ID: 7782-42-5

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2018-11-16

#: 4.0000 - 6.0000

GS: LT-UNK

RC: None

NANO: No

ROLE: intumescent material

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: intumescent material

UNDISCLOSED

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2018-11-16

#: 3.0000 - 5.0000

GS: BM-2

RC: None

NANO: No

ROLE: plasticizer

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: Contains no residuals.

UNDISCLOSED

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2018-11-16

#: 3.0000 - 5.0000

GS: LT-UNK

RC: None

NANO: No

ROLE: binder

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

UNDISCLOSED

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **1.0000 - 2.0000** GS: **LT-UNK** RC: **None** NANO: **No** ROLE: **binder component**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESPIRATORY	AOEC - Asthmagens	Asthmagen (G) - generally accepted
RESTRICTED LIST	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
SKIN IRRITATION	EU - GHS (H-Statements)	H315 - Causes skin irritation
SKIN SENSITIZE	EU - GHS (H-Statements)	H317 - May cause an allergic skin reaction
EYE IRRITATION	EU - GHS (H-Statements)	H319 - Causes serious eye irritation
RESPIRATORY	EU - GHS (H-Statements)	H334 - May cause allergy or asthma symptoms or breathing difficulties if inhaled
CANCER	EU - GHS (H-Statements)	H351 - Suspected of causing cancer
RESPIRATORY	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage
CANCER	MAK	Carcinogen Group 4 - Non-genotoxic carcinogen with low risk under MAK/BAT levels
RESPIRATORY	MAK	Sensitizing Substance Sah - Danger of airway & skin sensitization

SUBSTANCE NOTES: **No residuals are found in this material.**

UNDISCLOSED

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **0.3000 - 0.6000** GS: **LT-UNK** RC: **None** NANO: **No** ROLE: **binder component**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESTRICTED LIST	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
SKIN IRRITATION	EU - GHS (H-Statements)	H315 - Causes skin irritation
SKIN SENSITIZE	EU - GHS (H-Statements)	H317 - May cause an allergic skin reaction
EYE IRRITATION	EU - GHS (H-Statements)	H319 - Causes serious eye irritation
RESPIRATORY	EU - GHS (H-Statements)	H334 - May cause allergy or asthma symptoms or breathing difficulties if inhaled
CANCER	EU - GHS (H-Statements)	H351 - Suspected of causing cancer
RESPIRATORY	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage

SUBSTANCE NOTES: There are no residuals in this material.

UNDISCLOSED

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **0.2000 - 0.3000**

GS: **LT-UNK**

RC: **None**

NANO: **No**

ROLE: **catalyst**

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: No residuals are found in this material.

CARBON BLACK

ID: **1333-86-4**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **0.2000 - 0.4000**

GS: **LT-1**

RC: **None**

NANO: **No**

ROLE: **colorant**

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

CANCER

US CDC - Occupational Carcinogens

Occupational Carcinogen

CANCER

CA EPA - Prop 65

Carcinogen - specific to chemical form or exposure route

CANCER

IARC

Group 2B - Possibly carcinogenic to humans - inhaled from occupational sources

CANCER

MAK

Carcinogen Group 3B - Evidence of carcinogenic effects but not sufficient for classification

SUBSTANCE NOTES: Contains crystalline silica as a residual.

2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN

ID: **119-47-1**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **0.2000 - 0.4000**

GS: **LT-P1**

RC: **None**

NANO: **No**

ROLE: **antioxidant**

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

ENDOCRINE

TEDX - Potential Endocrine Disruptors

Potential Endocrine Disruptor

REPRODUCTIVE

Australia - GHS

H360F - May damage fertility

SUBSTANCE NOTES: No residuals are found in this material.

UNDISCLOSED

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **0.1000 - 0.2000**

GS: **LT-UNK**

RC: **None**

NANO: **No**

ROLE: **catalyst**

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: **No residuals are found in this material.**

2,5-FURANDIONE, 3-(DODECENYL)DIHYDRO-

ID: **25377-73-5**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **0.0500 - 0.1500**

GS: **LT-UNK**

RC: **None**

NANO: **No**

ROLE: **Surfactant**

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: **No residuals are found in this material.**

POLYPROPYLENE GLYCOL

ID: **25322-69-4**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2018-11-16**

#: **0.0500 - 0.1500**

GS: **LT-UNK**

RC: **None**

NANO: **No**

ROLE: **Polyol**

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: **No residuals are found in this product.**

Section 3: Certifications and Compliance

This section lists applicable certification and standards compliance information for VOC emissions and VOC content. Other types of health or environmental performance testing or certifications completed for the product may be provided.

VOC EMISSIONS

N/A

CERTIFYING PARTY: **Self-declared**

APPLICABLE FACILITIES: **All.**

CERTIFICATE URL:

https://files.stifirestop.com/5.%20Safety%20Data%20Sheets/1.%20English/SDS_EZ-Path%2044+.pdf

CERTIFICATION AND COMPLIANCE NOTES: **Not Applicable.**

ISSUE

EXPIRY

CERTIFIER OR

DATE:

DATE:

LAB: **Self-declared.**

2017-05-05

Section 4: Accessories

This section lists related products or materials that the manufacturer requires or recommends for installation (such as adhesives or fasteners), maintenance, cleaning, or operations. For information relating to the contents of these related products, refer to their applicable Health Product Declarations, if available.

No accessories are required for this product.

Section 5: General Notes

EZ Path® Series 22 Fire Rated Pathway is painted safety orange for easy identification. Its compact square profile allows a maximum number of cables to be installed in a relatively small area. The pathway measures approximately 1-1/2" x 1-1/2" (37 mm) and is 10-1/2" (267 mm) long. Applications EZ Path® Series 22 Fire Rated Pathway is designed for easy installation in walls. Tested and approved cable capacities range from 0 to 100% visual fill. EZ Path® Series 22 Fire Rated Pathway when installed with provided wall plates is designed for new cable installations. In these installations, the device does not require mechanical attachment to either the wall or the wall framing and may be installed after the wallboard has been installed. EZ Path® Series 22's split body design also allows the device to be easily disassembled and installed around previously installed cables in existing construction. EZ Path® Series 22 Fire Rated Pathway provides exceptional cable capacity. A single unit installed in a wall has an equal cable carrying capacity of a 2" (50 mm) diam sleeve utilizing typical putty firestop systems (35% cable loading). Specifications All data, video, and communications cable bundles shall utilize an enclosed firerated pathway device wherever said cables penetrate rated walls. The fire-rated pathway shall contain a built-in fire sealing system sufficient to maintain the hourly fire rating of the barrier being penetrated. The self-contained sealing system shall automatically adjust to the installed cable loading and shall permit cables to be installed, removed, or retrofitted without the need to remove or reinstall firestop materials. The pathway shall be UL Certified and tested to the requirements of ASTM E814 (UL1479) and CAN/ULC S115. Specified Divisions Division 7 07 84 13 Penetration Firestopping Division 26 26 00 00 Electrical Division 27 27 00 00 Communications Performance: EZ Path® Series 22 Fire Rated Pathway is UL Tested and Certified in accordance with ASTM E814 (UL1479) and CAN/ULC S115. Systems are available for common wall construction with ratings up to and including 4 hours. Features & Benefits • Easy to install • No firestopping required • Firestopped at all stages of use • UL Tested - Low Leakage! • UL Classified for the complete range of its capacity • Match the capacity of a 2" (50 mm) conduit • Acoustically Tested



MANUFACTURER INFORMATION

MANUFACTURER: **Specified Technologies Inc.**

ADDRESS: **210 Evans Way
Somerville NJ 08876, USA**

WEBSITE: **www.stifirestop.com**

CONTACT NAME: **George Gornick, LEED Green
Associate**

TITLE: **Applications Engineer**

PHONE: **800-992-1180 Ext. 1013**

EMAIL: **ggornick@stifirestop.com**

KEY

OSHA MSDS Occupational Safety and Health Administration Material Safety Data Sheet

GHS SDS Globally Harmonized System of Classification and Labeling of Chemicals Safety Data Sheet

Hazard Types

AQU Aquatic toxicity

CAN Cancer

DEV Developmental toxicity

END Endocrine activity

EYE Eye irritation/corrosivity

GEN Gene mutation

GLO Global warming

MAM Mammalian/systemic/organ toxicity

MUL Multiple hazards

NEU Neurotoxicity

OZO Ozone depletion

PBT Persistent Bioaccumulative Toxic

PHY Physical Hazard (reactive)

REP Reproductive toxicity

RES Respiratory sensitization

SKI Skin sensitization/irritation/corrosivity

LAN Land Toxicity

NF Not found on Priority Hazard Lists

GreenScreen (GS)

BM-4 Benchmark 4 (prefer-safer chemical)

BM-3 Benchmark 3 (use but still opportunity for improvement)

BM-2 Benchmark 2 (use but search for safer substitutes)

BM-1 Benchmark 1 (avoid - chemical of high concern)

BM-U Benchmark Unspecified (insufficient data to benchmark)

LT-P1 List Translator Possible Benchmark 1

LT-1 List Translator Likely Benchmark 1

LT-UNK List Translator Benchmark Unknown (insufficient information from List Translator lists to benchmark)

NoGS Unknown (no data on List Translator Lists)

Recycled Types

PreC Preconsumer (Post-Industrial)

PostC Postconsumer

Both Both Preconsumer and Postconsumer

Unk Inclusion of recycled content is unknown

None Does not include recycled content

Other Terms

Inventory Methods:

Nested Method / Material Threshold Substances listed within each material per threshold indicated per material

Nested Method / Product Threshold Substances listed within each material per threshold indicated per product

Basic Method / Product Threshold Substances listed individually per threshold indicated per product

Nano Composed of nano scale particles or nanotechnology

Third Party Verified Verification by independent certifier approved by HPDC

Preparer Third party preparer, if not self-prepared by manufacturer

Applicable facilities Manufacturing sites to which testing applies

The Health Product Declaration (HPD) Open Standard provides for the disclosure of product contents and potential associated human and environmental health hazards. Hazard associations are based on the HPD Priority Hazard Lists, the GreenScreen List Translator™, and when available, full GreenScreen® assessments. The HPD Open Standard v2.1 is not:

- a method for the assessment of exposure or risk associated with product handling or use,
- a method for assessing potential health impacts of: (i) substances used or created during the manufacturing process or (ii) substances created after the product is delivered for end use.

Information about life cycle, exposure and/or risk assessments performed on the product may be reported by the manufacturer in appropriate Notes sections, and/or, where applicable, in the Certifications section.

The HPD Open Standard was created and is supported by the Health Product Declaration Collaborative (the HPD Collaborative), a customer-led organization composed of stakeholders throughout the building industry that is committed to the continuous improvement of building products through transparency, openness, and innovation throughout the product supply chain.

The product manufacturer and any applicable independent verifier are solely responsible for the accuracy of statements and claims made in this HPD and for compliance with the HPD standard noted.