

**CLASSIFICATION:** 07 84 00 Firestopping, 07 84 13 Penetration Firestopping

**PRODUCT DESCRIPTION:** The SpecSeal® Series LCC Collar is a factory manufactured device designed to protect plastic pipes penetrating fire-rated walls and floors. Utilizing a heavy gauge galvanized metal collar to house a molded intumescent insert, the SpecSeal® Series LCC Firestop Collar is specifically sized to fit 1-1/2", 2", 3", and 4" (38mm, 51mm, 76mm and 102 mm) trade sized pipes. When exposed to temperatures in excess of 320°F (160°C), the SpecSeal® Series LCC Collar's molded insert begins to expand (intumesce) rapidly to form a dense, highly insulative char. Its free expansion ranges from 32-64 times original (pre-expanded) volume. Expansion continues up to 1,000°F (538°C). Applications SpecSeal® Series LCC Collars are used to protect a variety of plastic pipes including PVC, PVC Foam Core (ccPVC), CPVC, RNC, FRPP, FRP, ABS, and ABS Foam Core (ccABS) in both vented (DWV) and closed (electrical conduit and water supply) installations. SpecSeal® Series LCC Collars are suitable for use in all common constructions including concrete floors, concrete over steel deck, concrete walls, concrete block walls, gypsum board walls, as well as wood floor assemblies.

## Section 1: Summary Basic Method / Product Threshold

### CONTENT INVENTORY

**Inventory Reporting Format**

- Nested Materials Method
- Basic Method

**Threshold Disclosed Per**

- Material
- Product

**Threshold level**

- 100 ppm
- 1,000 ppm
- Per GHS SDS
- Per OSHA MSDS
- Other

**Residuals/Impurities**

- Considered
- Partially Considered
- Not Considered

Explanation(s) provided for Residuals/Impurities?  
 Yes  No

*All Substances Above the Threshold Indicated Are:*

**Characterized**  Yes Ex/SC  Yes  No  
*% weight and role provided for all substances.*

**Screened**  Yes Ex/SC  Yes  No  
*All substances screened using Priority Hazard Lists with results disclosed.*

**Identified**  Yes Ex/SC  Yes  No  
*One or more substances not disclosed by Name (Specific or Generic) and Identifier and/ or one or more Special Condition did not follow guidance.*

### CONTENT IN DESCENDING ORDER OF QUANTITY

Summary of product contents and results from screening individual chemical substances against HPD Priority Hazard Lists and the GreenScreen for Safer Chemicals®. The HPD does not assess whether using or handling this product will expose individuals to its chemical substances or any health risk. Refer to Section 2 for further details.

**MATERIAL | SUBSTANCE | RESIDUAL OR IMPURITY**  
**GREENSCREEN SCORE | HAZARD TYPE**

**SPECSEAL® SERIES LCC FIRESTOP COLLARS [ GRAPHITE LT-UNK UNDISCLOSED LT-UNK UNDISCLOSED NoGS UNDISCLOSED LT-UNK | RES | MUL | SKI | EYE | CAN 2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN LT-P1 | END | REP UNDISCLOSED LT-UNK | RES | MUL | CAN UNDISCLOSED LT-UNK | MUL | SKI | EYE | RES | CAN ]**

Number of Greenscreen BM-4/BM3 contents ... 0

Contents highest concern GreenScreen Benchmark or List translator Score ... LT-P1  
Nanomaterial ... No

**INVENTORY AND SCREENING NOTES:**  
None.

### VOLATILE ORGANIC COMPOUND (VOC) CONTENT

VOC Content data is not applicable for this product category.

### CERTIFICATIONS AND COMPLIANCE See Section 3 for additional listings.

VOC emissions: N/A

### CONSISTENCY WITH OTHER PROGRAMS

Pre-checked for LEED v4 Material Ingredients, Option 1

Third Party Verified?

- Yes
- No

PREPARER: Self-Prepared  
VERIFIER:  
VERIFICATION #:

SCREENING DATE: 2019-02-12  
PUBLISHED DATE: 2019-02-13  
EXPIRY DATE: 2022-02-12



## Section 2: Content in Descending Order of Quantity

This section lists contents in a product based on specific threshold(s) and reports detailed health information including hazards. This HPD uses the inventory method indicated above, which is one of three possible methods:

- Basic Inventory method with Product-level threshold.
- Nested Material Inventory method with Product-level threshold
- Nested Material Inventory method with individual Material-level thresholds

Definitions and requirements for the three inventory methods and requirements for each data field can be found in the HPD Open Standard version 2.1, available on the HPDC website at: [www.hpd-collaborative.org/hpd-2-1-standard](http://www.hpd-collaborative.org/hpd-2-1-standard)

### SPECSEAL® SERIES LCC FIRESTOP COLLARS

PRODUCT THRESHOLD: 1000 ppm

RESIDUALS AND IMPURITIES CONSIDERED: Yes

RESIDUALS AND IMPURITIES NOTES: There are no residuals in this product.

OTHER PRODUCT NOTES: There are no residuals in this product.

#### GRAPHITE

ID: 7782-42-5

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2019-02-12

%: 30.0000 - 60.0000

GS: LT-UNK

RC: None

NANO: No

ROLE: intumescent

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: This material is the intumescent in the product.

#### UNDISCLOSED

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2019-02-12

%: 20.0000 - 40.0000

GS: LT-UNK

RC: None

NANO: No

ROLE: binder

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: This material is part of the binder in the product.

#### UNDISCLOSED

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2019-02-12

%: 20.0000 - 40.0000

GS: NoGS

RC: None

NANO: No

ROLE: plasticizer

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: This material is the plasticizer in the product.

**UNDISCLOSED**HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**HAZARD SCREENING DATE: **2019-02-12**%: **1.0000 - 2.0000**GS: **LT-UNK**RC: **None**NANO: **No**ROLE: **binder**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESPIRATORY	AOEC - Asthmagens	Asthmagen (G) - generally accepted
RESTRICTED LIST	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
SKIN IRRITATION	EU - GHS (H-Statements)	H315 - Causes skin irritation
SKIN SENSITIZE	EU - GHS (H-Statements)	H317 - May cause an allergic skin reaction
EYE IRRITATION	EU - GHS (H-Statements)	H319 - Causes serious eye irritation
RESPIRATORY	EU - GHS (H-Statements)	H334 - May cause allergy or asthma symptoms or breathing difficulties if inhaled
CANCER	EU - GHS (H-Statements)	H351 - Suspected of causing cancer
RESPIRATORY	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage
CANCER	MAK	Carcinogen Group 4 - Non-genotoxic carcinogen with low risk under MAK/BAT levels
RESPIRATORY	MAK	Sensitizing Substance Sah - Danger of airway & skin sensitization

SUBSTANCE NOTES: **This material is part of the binder in the product.****2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN**ID: **119-47-1**HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**HAZARD SCREENING DATE: **2019-02-12**%: **0.3000 - 1.5000**GS: **LT-P1**RC: **None**NANO: **No**ROLE: **anti oxidant**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
ENDOCRINE	TEDX - Potential Endocrine Disruptors	Potential Endocrine Disruptor
REPRODUCTIVE	Australia - GHS	H360F - May damage fertility

SUBSTANCE NOTES: **This material is the anti oxidant in the product.****UNDISCLOSED**HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**HAZARD SCREENING DATE: **2019-02-12**%: **0.2000 - 0.8000**GS: **LT-UNK**RC: **None**NANO: **No**ROLE: **binder**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESPIRATORY	AOEC - Asthmagens	Asthmagen (G) - generally accepted
RESTRICTED LIST	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
RESPIRATORY	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage
CANCER	MAK	Carcinogen Group 4 - Non-genotoxic carcinogen with low risk under MAK/BAT levels
RESPIRATORY	MAK	Sensitizing Substance Sah - Danger of airway & skin sensitization

SUBSTANCE NOTES: This material is part of the binder in the product.

## UNDISCLOSED

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2019-02-12**

#: **0.1000 - 0.4000**

GS: **LT-UNK**

RC: **None**

NANO: **No**

ROLE: **binder**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESTRICTED LIST	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
SKIN IRRITATION	EU - GHS (H-Statements)	H315 - Causes skin irritation
SKIN SENSITIZE	EU - GHS (H-Statements)	H317 - May cause an allergic skin reaction
EYE IRRITATION	EU - GHS (H-Statements)	H319 - Causes serious eye irritation
RESPIRATORY	EU - GHS (H-Statements)	H334 - May cause allergy or asthma symptoms or breathing difficulties if inhaled
CANCER	EU - GHS (H-Statements)	H351 - Suspected of causing cancer
RESPIRATORY	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage

SUBSTANCE NOTES: This material is part of the binder in the product.

## Section 3: Certifications and Compliance

*This section lists applicable certification and standards compliance information for VOC emissions and VOC content. Other types of health or environmental performance testing or certifications completed for the product may be provided.*

### VOC EMISSIONS

N/A

CERTIFYING PARTY: **Self-declared**

ISSUE      EXPIRY      CERTIFIER

APPLICABLE FACILITIES: **All.**

DATE:      DATE:      OR LAB:

CERTIFICATE URL:

2017-      **Self-**

[https://files.stifirestop.com/5.%20Safety%20Data%20Sheets/1.%20English/SDS\\_LCC%20Collar.pdf](https://files.stifirestop.com/5.%20Safety%20Data%20Sheets/1.%20English/SDS_LCC%20Collar.pdf)

05-12

**declared.**

CERTIFICATION AND COMPLIANCE NOTES: **Not Applicable. SDS Attached (See Certificate URL).**

## Section 4: Accessories

*This section lists related products or materials that the manufacturer requires or recommends for installation (such as adhesives or fasteners), maintenance, cleaning, or operations. For information relating to the contents of these related products, refer to their applicable Health Product Declarations, if available.*

No accessories are required for this product.

## Section 5: General Notes

**Specifications** The firestop system shall be a factory assembled firestop collar utilizing a molded, flexible intumescent insert. The intumescent insert shall provide a minimum of 30X free expansion and shall contain no water soluble expansion ingredients. The specified material shall be approved for a wide range of applications including PVC, PVC Foam Core, CPVC, ABS, and ABS Foam Core pipes when used by itself or in combination with other products from the same manufacturer. The collar shall be UL Classified and tested to the requirements of ASTM E814 (UL1479). Specified Divisions Division 7 07 84 13 Penetration Firestopping Division 22 22 00 00 Plumbing Performance SpecSeal® Series LCC Collars are the basis for systems that meet the exacting criteria of ASTM E814 (UL1479). Systems have been tested for all common forms of masonry construction and the most common plastic pipes with ratings up to two hours. Consult factory for information not available in UL Fire Resistance Directory as of this printing. **Features & Benefits** • **Rapid Expansion:** Closes off burning pipes quickly. • **Small Profile:** Use it in all the tight spots! • **Flexible & Durable:** No loose flakes (eye hazards). • **Water Resistant:** No water soluble or hygroscopic ingredients. • **Economical:** Lower installed cost. • **High Volume Char:** Expands up to 60 times!

## MANUFACTURER INFORMATION

---

MANUFACTURER: **Specified Technologies Inc.**  
ADDRESS: **210 Evans Way**  
**Somerville NJ 08876, United States**  
WEBSITE: **www.stifirestop.com**

CONTACT NAME: **George Gornick, LEED Green Associate**  
TITLE: **Applications Engineer**  
PHONE: **800-992-1180 Ext. 1013**  
EMAIL: **ggornick@stifirestop.com**

## KEY

---

**OSHA MSDS** Occupational Safety and Health Administration Material Safety Data Sheet  
**GHS SDS** Globally Harmonized System of Classification and Labeling of Chemicals Safety Data Sheet

### Hazard Types

<b>AQU</b> Aquatic toxicity	<b>GLO</b> Global warming	<b>PHY</b> Physical Hazard (reactive)
<b>CAN</b> Cancer	<b>MAM</b> Mammalian/systemic/organ toxicity	<b>REP</b> Reproductive toxicity
<b>DEV</b> Developmental toxicity	<b>MUL</b> Multiple hazards	<b>RES</b> Respiratory sensitization
<b>END</b> Endocrine activity	<b>NEU</b> Neurotoxicity	<b>SKI</b> Skin sensitization/irritation/corrosivity
<b>EYE</b> Eye irritation/corrosivity	<b>OZO</b> Ozone depletion	<b>LAN</b> Land Toxicity
<b>GEN</b> Gene mutation	<b>PBT</b> Persistent Bioaccumulative Toxic	<b>NF</b> Not found on Priority Hazard Lists

### GreenScreen (GS)

<b>BM-4</b> Benchmark 4 (prefer-safer chemical)	<b>LT-P1</b> List Translator Possible Benchmark 1
<b>BM-3</b> Benchmark 3 (use but still opportunity for improvement)	<b>LT-1</b> List Translator Likely Benchmark 1
<b>BM-2</b> Benchmark 2 (use but search for safer substitutes)	<b>LT-UNK</b> List Translator Benchmark Unknown (insufficient information from List Translator lists to benchmark)
<b>BM-1</b> Benchmark 1 (avoid - chemical of high concern)	<b>NoGS</b> Unknown (no data on List Translator Lists)
<b>BM-U</b> Benchmark Unspecified (insufficient data to benchmark)	

### Recycled Types

**PreC** Preconsumer (Post-Industrial)  
**PostC** Postconsumer  
**Both** Both Preconsumer and Postconsumer  
**Unk** Inclusion of recycled content is unknown  
**None** Does not include recycled content

### Other Terms

#### Inventory Methods:

**Nested Method / Material Threshold** Substances listed within each material per threshold indicated per material  
**Nested Method / Product Threshold** Substances listed within each material per threshold indicated per product  
**Basic Method / Product Threshold** Substances listed individually per threshold indicated per product

**Nano** Composed of nano scale particles or nanotechnology  
**Third Party Verified** Verification by independent certifier approved by HPDC  
**Preparer** Third party preparer, if not self-prepared by manufacturer  
**Applicable facilities** Manufacturing sites to which testing applies

*The Health Product Declaration (HPD) Open Standard provides for the disclosure of product contents and potential associated human and environmental health hazards. Hazard associations are based on the HPD Priority Hazard Lists, the GreenScreen List Translator™, and when available, full GreenScreen® assessments. The HPD Open Standard v2.1 is not:*

- a method for the assessment of exposure or risk associated with product handling or use,*
- a method for assessing potential health impacts of: (i) substances used or created during the manufacturing process or (ii) substances created after the product is delivered for end use.*

*Information about life cycle, exposure and/or risk assessments performed on the product may be reported by the manufacturer in appropriate Notes sections, and/or, where applicable, in the Certifications section.*

*The HPD Open Standard was created and is supported by the Health Product Declaration Collaborative (the HPD Collaborative), a customer-led organization composed of stakeholders throughout the building industry that is committed to the continuous improvement of building products through transparency, openness, and innovation throughout the product supply chain.*

*The product manufacturer and any applicable independent verifier are solely responsible for the accuracy of statements and claims made in this HPD and for compliance with the HPD standard noted.*