

CLASSIFICATION: 07 84 00 Firestopping, 07 84 13 Penetration Firestopping

PRODUCT DESCRIPTION: SpecSeal® Wrap Strips are highly flexible, elastomeric strips designed to firestop combustible penetrations in fire-rated floors, floor/ceilings, and walls. Convenient 12' (3.7 m) rolls, or individually sized strips facilitate installation and minimize waste. These products utilize STI's fast responding intumescent technology, providing very responsive and highly directionalized expansion. Rapid expansion provides quick closure for burning combustible penetrants. When exposed to temperatures in excess of 250°F (121°C), the SpecSeal® Wrap Strip begins to expand (intumesce) rapidly to form a dense, highly insulative char. Free expansion varies according to the grade utilized (See Table A). Expansion continues up to temperatures of 1,000°F (538°C).

Section 1: Summary

Basic Method / Product Threshold

CONTENT INVENTORY

Inventory Reporting Format

- Nested Materials Method
- Basic Method

Threshold level

- 100 ppm
- 1,000 ppm
- Per GHS SDS
- Per OSHA MSDS
- Other

Residuals/Impurities

- Considered
- Partially Considered
- Not Considered

All Substances Above the Threshold Indicated Are:

Characterized Yes Ex/SC Yes No
% weight and role provided for all substances.

Threshold Disclosed Per

- Material
- Product

Explanation(s) provided for Residuals/Impurities?
 Yes No

Screened Yes Ex/SC Yes No
All substances screened using Priority Hazard Lists with results disclosed.

Identified Yes Ex/SC Yes No
One or more substances not disclosed by Name (Specific or Generic) and Identifier and/ or one or more Special Condition did not follow guidance.

CONTENT IN DESCENDING ORDER OF QUANTITY

Summary of product contents and results from screening individual chemical substances against HPD Priority Hazard Lists and the GreenScreen for Safer Chemicals®. The HPD does not assess whether using or handling this product will expose individuals to its chemical substances or any health risk. Refer to Section 2 for further details.

MATERIAL | SUBSTANCE | RESIDUAL OR IMPURITY
GREENSCREEN SCORE | HAZARD TYPE

SPECSEAL® SERIES SSW RED INTUMESCENT WRAP STRIP [GRAPHITE LT-UNK
UNDISCLOSED LT-UNK UNDISCLOSED LT-UNK UNDISCLOSED LT-P1 | END
UNDISCLOSED BM-2 | RES ZINC OXIDE BM-1 | RES | AQU | MUL METHYLENE
BISPHENYL DIISOCYANATE (PURE MDI) LT-UNK | RES | MUL | SKI | EYE | CAN 2,2'-
BIS-6-TERC.BUTYL-P-KRESYLMETHAN LT-P1 | END | REP]

Number of Greenscreen BM-4/BM3 contents ... 0
Contents highest concern GreenScreen Benchmark or List translator Score ... BM-1
Nanomaterial ... No

INVENTORY AND SCREENING NOTES:
None.

VOLATILE ORGANIC COMPOUND (VOC) CONTENT

VOC Content data is not applicable for this product category.

CERTIFICATIONS AND COMPLIANCE *See Section 3 for additional listings.*

VOC emissions: N/A

CONSISTENCY WITH OTHER PROGRAMS

Pre-checked for LEED v4 Material Ingredients, Option 1

Third Party Verified?

- Yes
- No

PREPARER: Self-Prepared

VERIFIER:
VERIFICATION #:

SCREENING DATE: 2019-03-20

PUBLISHED DATE: 2019-03-21

EXPIRY DATE: 2022-03-20



Section 2: Content in Descending Order of Quantity

This section lists contents in a product based on specific threshold(s) and reports detailed health information including hazards. This HPD uses the inventory method indicated above, which is one of three possible methods:

- Basic Inventory method with Product-level threshold.
- Nested Material Inventory method with Product-level threshold
- Nested Material Inventory method with individual Material-level thresholds

Definitions and requirements for the three inventory methods and requirements for each data field can be found in the HPD Open Standard version 2.1, available on the HPDC website at: www.hpd-collaborative.org/hpd-2-1-standard

SPECSEAL® SERIES SSW RED INTUMESCENT WRAP STRIP

PRODUCT THRESHOLD: 1000 ppm

RESIDUALS AND IMPURITIES CONSIDERED: Yes

RESIDUALS AND IMPURITIES NOTES: There are no residuals in this product.

OTHER PRODUCT NOTES: There are no residuals in this product.

GRAPHITE

ID: 7782-42-5

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2019-03-20

#: 20.0000 - 40.0000

GS: LT-UNK

RC: None

NANO: No

ROLE: Intumescent

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: This is the intumescent in the product.

UNDISCLOSED

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2019-03-20

#: 15.0000 - 30.0000

GS: LT-UNK

RC: None

NANO: No

ROLE: binder

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: This material is part of the binder in the product.

UNDISCLOSED

HAZARD SCREENING METHOD: Pharos Chemical and Materials Library

HAZARD SCREENING DATE: 2019-03-20

#: 10.0000 - 30.0000

GS: LT-UNK

RC: None

NANO: No

ROLE: flame retardant

HAZARD TYPE

AGENCY AND LIST TITLES

WARNINGS

No hazards found

SUBSTANCE NOTES: This material is the flame retardant in the product.

UNDISCLOSED

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2019-03-20**

#: **8.0000 - 20.0000**

GS: **LT-P1**

RC: **None**

NANO: **No**

ROLE: **plasticizer**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
ENDOCRINE	ChemSec - SIN List	Endocrine Disruption

SUBSTANCE NOTES: **This material is the plasticizer in the product.**

UNDISCLOSED

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2019-03-20**

#: **8.0000 - 22.0000**

GS: **BM-2**

RC: **None**

NANO: **No**

ROLE: **flame retardant**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESPIRATORY	AOEC - Asthmagens	Asthmagen (Rs) - sensitizer-induced

SUBSTANCE NOTES: **This material is a flame retardant in the product.**

ZINC OXIDE

ID: **1314-13-2**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2019-03-20**

#: **2.0000 - 6.0000**

GS: **BM-1**

RC: **None**

NANO: **No**

ROLE: **mildewcide**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESPIRATORY	AOEC - Asthmagens	Asthmagen (Rs) - sensitizer-induced
ACUTE AQUATIC	EU - GHS (H-Statements)	H400 - Very toxic to aquatic life
CHRON AQUATIC	EU - GHS (H-Statements)	H410 - Very toxic to aquatic life with long lasting effects
MULTIPLE	German FEA - Substances Hazardous to Waters	Class 2 - Hazard to Waters

SUBSTANCE NOTES: **This material is the mildewcide in the product.**

METHYLENE BISPHENYL DIISOCYANATE (PURE MDI)

ID: **101-68-8**

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2019-03-20**

#: **1.0000 - 6.0000**

GS: **LT-UNK**

RC: **None**

NANO: **No**

ROLE: **Binder**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
RESPIRATORY	AOEC - Asthmagens	Asthmagen (G) - generally accepted
RESTRICTED LIST	US EPA - PPT Chemical Action Plans	EPA Chemical of Concern - Action Plan published
SKIN IRRITATION	EU - GHS (H-Statements)	H315 - Causes skin irritation
SKIN SENSITIZE	EU - GHS (H-Statements)	H317 - May cause an allergic skin reaction
EYE IRRITATION	EU - GHS (H-Statements)	H319 - Causes serious eye irritation
RESPIRATORY	EU - GHS (H-Statements)	H334 - May cause allergy or asthma symptoms or breathing difficulties if inhaled
CANCER	EU - GHS (H-Statements)	H351 - Suspected of causing cancer
RESPIRATORY	US EPA - PPT Chemical Action Plans	Inhalation sensitizer causing asthma and lung damage
CANCER	MAK	Carcinogen Group 4 - Non-genotoxic carcinogen with low risk under MAK/BAT levels
RESPIRATORY	MAK	Sensitizing Substance Sah - Danger of airway & skin sensitization

SUBSTANCE NOTES: This material is part of the binder in the product.

2,2'-BIS-6-TERC.BUTYL-P-KRESYLMETHAN

ID: 119-47-1

HAZARD SCREENING METHOD: **Pharos Chemical and Materials Library**

HAZARD SCREENING DATE: **2019-03-20**

#: **0.5000 - 1.5000**

GS: **LT-P1**

RC: **None**

NANO: **No**

ROLE: **antioxidant**

HAZARD TYPE	AGENCY AND LIST TITLES	WARNINGS
ENDOCRINE	TEDX - Potential Endocrine Disruptors	Potential Endocrine Disruptor
REPRODUCTIVE	Australia - GHS	H360F - May damage fertility

SUBSTANCE NOTES: This material is the antioxidant in the product.

Section 3: Certifications and Compliance

This section lists applicable certification and standards compliance information for VOC emissions and VOC content. Other types of health or environmental performance testing or certifications completed for the product may be provided.

VOC EMISSIONS

N/A

CERTIFYING PARTY: **Self-declared**

ISSUE DATE: EXPIRY DATE: CERTIFIER OR LAB:

APPLICABLE FACILITIES: **All.**

2017-09-07

CERTIFICATE URL:

https://files.stifirestop.com/5.%20Safety%20Data%20Sheets/1.%20English/SDS_RED%20Wrap%20Strip.pdf

Self-declared.

CERTIFICATION AND COMPLIANCE NOTES: **Not applicable. Not a wet applied product or type of insulation. See SDS under Certificate URL.**

Section 4: Accessories

This section lists related products or materials that the manufacturer requires or recommends for installation (such as adhesives or fasteners), maintenance, cleaning, or operations. For information relating to the contents of these related products, refer to their applicable Health Product Declarations, if available.

No accessories are required for this product.

Section 5: General Notes

Applications SpecSeal® Wrap Strips are used for firestopping combustible penetrants such as nonmetallic pipes or pipe insulation. Installations were developed for both “tuck-in” applications (where strips are secured around the penetrant and slid into the opening) and restraining collar assemblies (for surface mounting). For larger openings or complex penetrant configurations, systems were developed utilizing wrap strips in conjunction with other SpecSeal® products. SpecSeal® Wrap Strips are suitable for use in all common forms of construction including concrete floors, concrete over steel deck, concrete walls, concrete block walls, gypsum board/stud walls, and wood floor/ceiling assemblies. Specifications The wrap strip material shall be a highly flexible, intumescent material. The wrap strip shall contain no water soluble expansion ingredients and provide a minimum of 16x free expansion. The intumescent wrap strip shall be faced on each side with plastic. The specified material shall be approved for a wide range of applications including combustible and noncombustible penetrants when used by itself or in combination with other products from the same manufacturer. The wrap strip shall be UL Certified and tested to the requirements of ASTM E814 (UL 1479), CAN/ULC S115. Specified Divisions Division 7 07 84 13 Penetration Firestopping Division 22 22 00 00 Plumbing Performance SpecSeal® Wrap Strips are the basis for systems that meet the exacting criteria of ASTM E814 (UL 1479), CAN/ULC S115. Systems were tested for all common forms of construction and penetrants with ratings up to 4 hours (dependent upon grade of wrap strip utilized). Features & Benefits • Rapid Expansion: Closes off burning penetrants faster. • High Volume Char: Significant expansion seals off opening! • Water-Resistant: No soluble or hygroscopic ingredients. • Economical: 12' (3.7 m) rolls or precut strips means no piecing...less waste! • Highly Flexible: No foil...soft...supple...easier to install! • Versatile: Performer for a wide range of complex applications.



Section 6: References

MANUFACTURER INFORMATION

MANUFACTURER: **Specified Technologies Inc.**
 ADDRESS: **210 Evans Way**
Somerville NJ 08876, United States
 WEBSITE: **www.stifirestop.com**

CONTACT NAME: **George Gornick, LEED Green Associate**
 TITLE: **Applications Engineer**
 PHONE: **800-992-1180, Ext. 1013**
 EMAIL: **ggornick@stifirestop.com**

KEY

OSHA MSDS Occupational Safety and Health Administration Material Safety Data Sheet
GHS SDS Globally Harmonized System of Classification and Labeling of Chemicals Safety Data Sheet

Hazard Types

AQU Aquatic toxicity	GLO Global warming	PHY Physical Hazard (reactive)
CAN Cancer	MAM Mammalian/systemic/organ toxicity	REP Reproductive toxicity
DEV Developmental toxicity	MUL Multiple hazards	RES Respiratory sensitization
END Endocrine activity	NEU Neurotoxicity	SKI Skin sensitization/irritation/corrosivity
EYE Eye irritation/corrosivity	OZO Ozone depletion	LAN Land Toxicity
GEN Gene mutation	PBT Persistent Bioaccumulative Toxic	NF Not found on Priority Hazard Lists

GreenScreen (GS)

BM-4 Benchmark 4 (prefer-safer chemical)	LT-P1 List Translator Possible Benchmark 1
BM-3 Benchmark 3 (use but still opportunity for improvement)	LT-1 List Translator Likely Benchmark 1
BM-2 Benchmark 2 (use but search for safer substitutes)	LT-UNK List Translator Benchmark Unknown (insufficient information from List Translator lists to benchmark)
BM-1 Benchmark 1 (avoid - chemical of high concern)	NoGS Unknown (no data on List Translator Lists)
BM-U Benchmark Unspecified (insufficient data to benchmark)	

Recycled Types

PreC Preconsumer (Post-Industrial)
PostC Postconsumer
Both Both Preconsumer and Postconsumer
Unk Inclusion of recycled content is unknown
None Does not include recycled content

Other Terms

Inventory Methods:

Nested Method / Material Threshold Substances listed within each material per threshold indicated per material
Nested Method / Product Threshold Substances listed within each material per threshold indicated per product
Basic Method / Product Threshold Substances listed individually per threshold indicated per product

Nano Composed of nano scale particles or nanotechnology
Third Party Verified Verification by independent certifier approved by HPDC
Preparer Third party preparer, if not self-prepared by manufacturer
Applicable facilities Manufacturing sites to which testing applies

The Health Product Declaration (HPD) Open Standard provides for the disclosure of product contents and potential associated human and environmental health hazards. Hazard associations are based on the HPD Priority Hazard Lists, the GreenScreen List Translator™, and when available, full GreenScreen® assessments. The HPD Open Standard v2.1 is not:

- a method for the assessment of exposure or risk associated with product handling or use,
- a method for assessing potential health impacts of: (i) substances used or created during the manufacturing process or (ii) substances created after the product is delivered for end use.

Information about life cycle, exposure and/or risk assessments performed on the product may be reported by the manufacturer in appropriate Notes sections, and/or, where applicable, in the Certifications section.

The HPD Open Standard was created and is supported by the Health Product Declaration Collaborative (the HPD Collaborative), a customer-led organization composed of stakeholders throughout the building industry that is committed to the continuous improvement of building products through transparency, openness, and innovation throughout the product supply chain.

The product manufacturer and any applicable independent verifier are solely responsible for the accuracy of statements and claims made in this HPD and for compliance with the HPD standard noted.